





TANK DRY WEIGHT APPROX. 80KGS

FABRICATION NOTES



ALWAYS REFER TO PLAN VIEW
FOR TRUE ORIENTATIONS




GENERAL TOLERANCE +10mm -10mm
DRAWING PRODUCED USING AUTODESK
INVENTOR
DO NOT ALTER MANUALLY
DO NOT SCALE - IF IN DOUBT ASK
ALL DIMENSIONS IN MILLIMETRES UNLESS STATED
ALWAYS REFER TO PLAN VIEW
FOR CORRECT ORIENTATION
ALL WELDS TO BE
6x3mm CORD WELDS UNLESS STATED

DESIGN DATA	
DESIGN CODE	BS EN 12573
DESIGN PRESSURE	ATMOSPHERIC
OPERATING PRESSURE	ATMOSPHERIC
CONTENTS	
SPECIFIC GRAVITY	
DESIGN TEMPERATURE	
OPERATING TEMPERATURE	
WORKING CAPACITY	
MAXIMUM CAPACITY	
FABRICATION SPECIFICATION	
BASE	
LID	
BACKING RINGS	
GASKETS	
PASTENERS	A2 STAINLESS STEEL

APPROVED
WORKING DRAWING
SIGNED: NAME: DATE:
THE INFORMATION ON THIS DRAWING IS STRICTLY CONFIDENTIAL
TO CHEM-RESIST GROUP LTD AND SHALL NOT BE DISCLOSED TO A THIRD
PARTY WITHOUT PRIOR WRITTEN CONSENT ©COPYRIGHT 1998
INSPECTION AND TESTING
BS EN ISO 9001 QUALITY ASSURANCE IN PROCESS INSPECTION
TANK TO BE FILLED WITH WATER FOR 24 HOURS MINIMUM

DRAWING No TITLE		RELATED DRAWINGS	
REVISIONS			
REV	AMENDMENT	DATE	BY
0	Preliminary Issue	4/6/19	JR



BRITANIA HOUSE
LOCKNEY
RAVENSTHORPE INDUSTRIAL ESTATE
CROSBURY
WEST YORKSHIRE
WF11 3JL
ENGLAND
Tel: +44 (0) 1524 491666
Fax: +44 (0) 1524 491334
Email: enquiry@chemresist.com
WWW.HTTP://WWW.CHEMRESIST.COM

JOB No:	CE No:	MAT:	PE009
CLIENT:	CHEM RESIST		
TITLE	PUMPED DISCHARGE CHEMIGUARD	SCALE:	A1
DRAWN BY:	JOE R	DRG No:	PUMPED DISCHARGE
DATE:	4/6/19	CHEMIGUARD	Sheet 1 of 1